

From: [Gray, David](#)
To: [Maguire, Charles](#)
Cc: [Crossland, Ronnie](#); [Garcia, David](#); [McDonald, James](#); [Hill, Troy](#); [McQuiddy, David](#); [Edlund, Carl](#); [Brown, Jamesr](#); [Smalley, Bryant](#)
Subject: Re: Craft-Turney WSC, South Cherokee County, Texas
Date: Friday, October 5, 2018 8:32:58 AM

Great. Charles, I will be expecting these routine updates from you. Please follow my draft format as much as possible.

David

Sent from my iPhone

On Oct 5, 2018, at 8:13 AM, Maguire, Charles <maguire.charles@epa.gov> wrote:

Be accurate and quick- thx

Sent from my iPhone

On Oct 5, 2018, at 8:11 AM, Crossland, Ronnie <Crossland.Ronnie@epa.gov> wrote:

David

Charles and I have talked and water is taking the lead right now unless we have to respond. They will continue to coordinate with TCEQ and provide updates. WQ, SF & MD are working together to support TCEQ. With the exception of analytical support, TCEQ is addressing the incident. They are flushing the system and are providing bottled water.

Thanks
Ronnie

Sent from my iPhone

On Oct 5, 2018, at 7:17 AM, Gray, David <gray.david@epa.gov> wrote:

All - I need an update this morning as soon as possible.
Who is the lead? Also, I will need updates over the weekend. Here is my rough draft.
David

Craft-Turney WSC, South Cherokee County, Texas

update

We continue to assist with TCEQ on a public water supply contamination issue.

TCEQ learned that the product is a type of commercial fungicide . MSDS sheets have been provided to the TCEQ Toxicology which are under review. The TCEQ is coordinating with the WSC on a sampling plan.

Sampling will begin on October 4, 2018.

Background

Craft-Turney WSC, located in South Cherokee County, South of Jacksonville, issued a Do Not Use order 10/3/18, on 16 connections related to a back siphonage event at Arrington Sawmill.

On 9/29/18 the water system repaired a water line break.

On 10/01/18 the water system received complaints of water quality including burning or irritated skin after exposure to the water. The water system believes a back siphonage may have occurred during the line break repair. Samples were collected and the system is waiting on the lab results.

TCEQ determined a tank containing a wood preservative, for treating wood pallets did not have a backflow prevention device.

Early reports that the fungicide was part of the PFAS family of chemicals is incorrect.

Texas has issued do not drink water order and a sampling plan to test the drinking water system.

TCEQ has requested EPA Assistance with developing a method for MBT (methylene bis-thiocyanate), so they can make a declaration about the absence/presence of it in the Drinking Water before lifting the do not use order.

Approximately 1,500 hundred now under bottled water restrictions.

Press

<https://www.easttexasmatters.com/news/local-news/craft-turney-water-supply-issues-do-not-use-order-to-customers/1496197618>

Sent from my iPhone